

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHEISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 2140068

Ordering firm: ZPA EKOREG, spol. s r. o.
Děčínská 55, 400 03 Ústí nad Labem, Czech Republic

Manufacturer/Licence holder: ZPA EKOREG, spol. s r. o.
Děčínská 55, 400 03 Ústí nad Labem, Czech Republic

Name of product: Pressure switch

Trade name:

Type of product: TSA01262 - variants: TSA2S05S, TSA2S10S, TSA2S05M, TSA2S10M, TSA2K05S, TSA2K10S,
TSA2K05M, TSA2K10M
TSA01263 - variants: TSA3V05S, TSA3V10S, TSA3V05M, TSA3V10M

Rating: 500 V/6 A, 400 V/10 A, 250 V/16 A, nominal pressure of 1 MPa

Electrotechnical Testing Institute on the basis of fulfillment the requirements of the „ESC Mark” certification scheme is granting a licence for using the following mark



This mark may be used for the product specified in this certificate within validity of the Agreement on the use of the ESC Mark by implementing all the rules stated in the Agreement.

The right to use the above mentioned mark for the product is based on:

- Test report No. 403625-01/01 of: 04.12.2014

A sample of the product was tested and found to be in conformity with:

ČSN EN 60730-1:01 ed.2+A11:02+A12:04+A1:05+A13:05+A14:05+A15:07+A16:07+1:07+A2:09,
ČSN EN 60730-2-6:97+A1:98+A2:99+1:02+Z1:09, ČSN EN 60730-2-6:09 ed.2

- inspection at manufacturing site according to Permanent Documents CIG 023 and CIG 024 No. 305599-01 of 17.12.2013
- the Agreement on the use of the ESC Mark No. 403625 concluded between the ordering firm and the Electrotechnical Testing Institute

12.12.2014

Prague

Miroslav Sedláček
Head of Certification Body



403625-01